

Map ID  
Direction  
Distance  
Elevation

MAP FINDINGS

EDR ID Number  
EPA ID Number

FB779  
ENE  
> 1  
1.079 mi.  
5699 ft.

CONEY ISLAND GETS RUPTURE  
CONEY ISLAND STP  
NEW YORK CITY, NY

NY Spills S102143992  
N/A

Site 5 of 6 in cluster FB

Relative:  
Higher

Actual:  
10 ft.

SPILLS:

Name:	CONEY ISLAND GETS RUPTURE
Address:	CONEY ISLAND STP
City,State,Zip:	NEW YORK CITY, NY
Spill Number/Closed Date:	8601590 / 1986-06-06
Facility ID:	8601590
Facility Type:	ER
DER Facility ID:	63182
Site ID:	65899
DEC Region:	2
Spill Cause:	Equipment Failure
Spill Class:	D4
SWIS:	2401
Spill Date:	1986-06-06
Investigator:	SJMILLER
Referred To:	Not reported
Reported to Dept:	1986-06-06
CID:	Not reported
Water Affected:	PAERDEGAAT BASIN
Spill Source:	Institutional, Educational, Gov., Other
Spill Notifier:	Responsible Party
Cleanup Ceased:	1986-06-06
Cleanup Meets Std:	True
Last Inspection:	Not reported
Recommended Penalty:	False
UST Trust:	False
Remediation Phase:	0
Date Entered In Computer:	1986-07-02
Spill Record Last Update:	1997-10-15
Spiller Name:	Not reported
Spiller Company:	NYCDEP
Spiller Address:	Not reported
Spiller Company:	001
Contact Name:	Not reported
DEC Memo:	"Prior to Sept, 2004 data translation this spill Lead_DEC Field was MILLER 10/10/95: This is additional information about material spilled from the translation of the old spill file: UNK. AMT"
Remarks:	"RUPTURED AIRLINE AT PLANT CAUSED BYPASS; BYPASS LASTED 1 HR. LINE REPAIRED BY DEP"